

# CITY OF CAMILLA

## 2017 WATER QUALITY REPORT

### QUALITY WATER FOR TODAY

Public Water System I.D. #205-0001


JUNE 25, 2018

The City of Camilla Utilities Department and specifically the Water Department employees are committed to providing its citizens with safe and of superior quality drinking water. Our goal is to keep the drinking water meeting or exceeding state and federal regulations for safe drinking water.

Where does this water come from?

Is it safe for you and your children?

This annual Water Quality Report will answer those questions for you. A copy of this report is available for you at City Hall/ Customer Service. Stop by anytime during normal business hours and pick one up.



**El informe contiene informacion importante sobre la calidad del agua en su comunidad.**

## CAMILLA WATER QUALITY EXCEEDS SAFE STANDARDS

Customers of the City of Camilla water supply are fortunate to have one of the finest sources of drinking water available. Our water is collected from deep in the ground, taken out of what is known as the Floridan Aquifer, the state's largest aquifer. The Floridan extends from near Dawson southeast into the Atlantic Ocean. This water is deep enough in the ground that it is very unlikely to be as easily contaminated as water that is above ground, such as lakes and rivers.

Camilla has four deep wells that provide water to be contained in raised, clean and well maintained water storage towers. The transfer of the water from underground to enclosed towers protects it from contaminants such as pesticides, heavy metals and other chemicals. During the collection, storage and delivery chlorine and fluoride are added to the water. Chlorine is added for disinfection and fluoride is added to promote strong

teeth.


To ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (EPA) sets limits on the amount of certain contaminants (over 100 of them) allowed to be in drinking water provided by public water systems. The City, with assistance from the Georgia Environmental Protection Division Water Quality Laboratory, performs several thousand tests annually on our water to monitor continued compliance with these regulations.

Even with all of this, drinking water, including bottled water, may reasonably be expected to contain small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791). For questions about our water quality or copies of this report, call City Hall at 336-2220.

As a public utilities company, Camilla Utilities is

governed by your elected members of the Camilla City Council which sits as the Board of Utilities. The public is urged to attend Council meetings. A schedule of City Council meetings is available at City Hall, 30 East Broad Street.

We encourage and invite public interest in community decision-making processes affecting drinking water. If you have any information or concerns about our drinking water you may contact City Hall (336-2220) or any elected member of your City Council.



## WATER QUALITY REPORT 2017

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be at particular risk from infections. These people should seek advice about drinking water from their health care providers. EPA and the Center for Disease Control guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

### WHERE DOES DRINKING WATER COME FROM?

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that could be present in source water include the following:

# Microbial contaminants, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

# Inorganic contaminants such as salts and metals which can be naturally occurring or a result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

# Pesticides and herbicides which may come from a variety of sources such as agriculture, urban storm runoff and residential uses.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Camilla is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in the drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/>

### WHAT IS IN OUR DRINKING WATER

#### TERMS AND ABBREVIATIONS USED BELOW:

**PPM** = parts per million-one part per million is equivalent to one penny in \$10,000

**PPB** = parts per billion-one part per billion is equivalent to one penny in \$10,000,000

**MCLG** = Maximum Contaminant Level Goal. The level of a contaminant in drinking water below which there is no known or expected risk to health.

SUBSTANCE DETECTED	UNIT OF MEASURE	GOAL MCLG	MAXIMUM ALLOWED MCL	AMOUNT DETECTED	IS IT SAFE? DOES IT MEET STANDARDS?	PROBABLE SOURCE
	LEAD	PPB	0	AL=15	4.3	YES
COPPER	PPB	1300	AL=1300	520	YES	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
CHLORINE	PPM	>0.2	<1.2	0.29	YES	Additive for disinfection